

PANVEL MUNICIPAL CORPORATION Tal, Panyel, Dist. Raigad. Pin No. 410206

Office No- 27458040/41/42 Fire Office No- 27461500

Email-Panvelcorporation@gmail.com

Fax No- 022-27452233

Outword/No/Pmc/Fire/2121/Ref. No.1257/2023/926 Date-28/06/2023

APPENDIX - VII

FIRE SAFETY CERTIFICATE

Certified that the M/S. NEW JAI BHARAT SHIKSHAN PRASARAK MANDAL at Plot No.27, Sec-02, New Panvel, Navi Mumbai comprised of Ground + 3 Upper Floor owned / occupied by M/S. SHANTINIKETAN PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 26/07/2023 in the presence of Principal Dr. Paiker Seemav & M/s. Arya IBMS Enterprises, Fire License Agency and that the building/premises is fit for occupancy up to Class XII with effect from 26/07/2023 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended -

1) In build Fire Fighting System Should be kept in good working condition all the time.

2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of January & July) & produce the Form 'B' certificate to this

3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 26/07/2023 at Navi Mumbai by

Signature with Seal: : Pravin B. Bodkhe

Name

: Chief Fire Officer

Name & Address of Department / Office: Panvel Municipal Corporation

PRAVIN BALU BODKHE CHIEF FIRE OFFICER PANVEL MUNICIPAL CORPORATON

Principal,

To.

M/S. NEW JAI BHARAT SHIKSHAN PRASARAK MANDAL

M/S. SHANTINIKETAN PUBLIC SCHOOL

Plot No. 27, Sec-02,

New Panvel, Navi Mumbai