



PANVEL MUNICIPAL CORPORATION

Tal. Panvel, Dist. Raigad. Pin No. 410206



Office No- 27458040/41/42

Fire Office No- 27461500

Email-Panvelcorporation@gmail.com

Fax No- 022-27452233

Outword/No/Pmc/Fire/ 2121/Ref. No.1257/2226023/ १४०४ /2025

Date- ०५/०८/2025

APPENDIX - VII

FIRE SAFETY CERTIFICATE

Certified that the M/S. SHANTINIKETAN PUBLIC SCHOOL at Plot No. 27/28, Sector-02, New Panvel, Navi Mumbai comprised of Ground + 3rd Upper Floor owned / occupied by M/S. NEW JAI BHARAT SHIKSHAN PRASARAK MANDAL's have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 26/06/2024 in the presence of Principal Dr. Paiker Seemav / M/s. Safe House Fire Engineering Services, Fire License Agency and that the building/premises is fit for occupancy up to Class XII with effect from 26/06/2024 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended :-

- 1) In build Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of July & December) & produce the Form 'B' certificate to this department
- 3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 24/07/2025 at Navi Mumbai by

Signature with Seal :

Name : Pravin B. Bodkhe

Designation : Chief Fire Officer

Name & Address of Department / Office: Panvel Municipal Corporation

मुख्य अग्निशमन अधिकारी
पनवेल महानगरपालिका

To,
Principal,
M/S. SHANTINIKETAN PUBLIC SCHOOL
M/S. NEW JAI BHARAT SHIKSHAN PRASARAK MANDAL's
Plot No. 27/28, Sector-02, New Panvel, Navi Mumbai

Principal
Shantiniketan Public School
Plot No. 27, Sector-2,
New Panvel, Dist.-Raigad.

